

## CERTIFICATE OF APPROVAL No CS 5082

This is to certify that, in accordance with  
STS200 General Requirements for Certification of Enhanced Security Products  
The undermentioned products of

### DOORPAC LTD

2 Ranskill Court, Sheffield, South Yorkshire, S9 5FZ  
Tel: 0114 256 1615

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:


**CERTIFIED PRODUCT**  
Homeguard Internal Security Doorset

**TECHNICAL SCHEDULE**  
STS201 - Enhanced security  
requirements for doorsets to satisfy  
the requirements of PAS24

CLASSIFICATION			
Security	Weather	Strength	Material Specific
PAS24 D	BS6375-1 800U	BS6375-2&3 Medium Duty	NPD

NPD = No performance determined

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited



Paul Duggan  
Certification Manager



Issued: 3<sup>rd</sup> October 2016  
Revised: 17<sup>th</sup> August 2022  
Valid to: 1<sup>st</sup> July 2026



---

## CERTIFICATE No CS 5082 DOORPAC LTD

---

### Doorpac Ltd – Homeguard Internal Security Doorsets

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the use of the above in providing an enhanced security performance to PAS24:2016 Annex A & B, a weather performance of 800U to BS6375-1:2015 and a mechanical strength performance of Medium Duty to BS6375-2:2009, and an additional performance to Annex A & C of BS6375-3:2009.
3. The doorsets are approved on the basis of:
  - i. Initial type testing against PAS24 & BS6375. Element Wednesbury test reports WIL358543, WIL358544, WIL358545, WIL377471, WIL377473, WIL386604, WIL386605, WIL386606, WIL 408316-1, WIL 408316-2, WIL 408317, WIL 408318, WIL 424994, WIL 424995, WIL 424996, WIL 424997, WIL 424998, WIL 424999, WIL 428172, WIL 437491, WIL 502743, WIL 515882 & WIL 516439
  - ii. Audit testing at the frequency specified in STS 200 & STS 201 where relevant.
  - iii. A design appraisal against STS201 where relevant.
  - iv. Inspection and surveillance of factory production control at 2 Ranskill Court, Sheffield, South Yorkshire, S9 5FZ.
4. This approval is applicable to complete doorsets only.
5. This certification is designed to demonstrate compliance of the doorset specifically with PAS24 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
6. This approval is applicable to single-leaf, glazed or unglazed, open-in & open-out doorsets without sidelights & toplights, with or without letterplates at leaf dimensions up to those given in Table 1.

---

## CERTIFICATE No CS 5082 DOORPAC LTD

---

### Doorpac Ltd – Homeguard Internal Security Doorsets

7. Approved hardware items are:
- 3no. Carlisle Brass Grade 13 ball bearing hinge (44mm & 54mm Strebord leaf) or 3no. Arrone AR8182 Grade 13 Ball Bearing Hinge (44mm Strebord & Flamebreak leaf) or 4no. Arrone AR8182 Grade 13 Ball Bearing Hinge (54mm Strebord leaf only)
  - GU Secury automatic A2 multipoint lock or Salto Mortice Escape Lock XS4 LE7S15 or Salto Mortice Lock XS4 LE7S05 or Salto Mortice Lock XS4 LE7S25 or Dorma 392CE B Night Latch with GK231M Electric Release Keep (all 54mm Strebord leaf only)
  - Salto Networked Electronic Handle range XS4 E9451/E9450 (with or without internal thumbturn) or XS4 EB451/EB450 Bluetooth (with or without internal thumbturn), or XS4 One E9751/E9750 (with or without internal thumbturn) or XS4 One EB751/EB750 Bluetooth) (with or without internal thumbturn) or Hoppe 3259N-ZA, 3259N-ZA (V4), 3260N-ZA, M3259N-ZA, M3260N-ZA 2\* Security Handle or Carlisle Brass Range of Lever Handles & Securefast / Apecs Security escutcheon SSEDKC or UAP 2\* rated HSE Escutcheon or Consort 'D' shaped pull handle CPHH15, CPHH8 or CPHH9 & Securefast / Apecs Security escutcheon SSEDKC or UAP 2\* rated HSE Escutcheon
  - Access2 Tigris Premier 3 1\* cylinder, Access2 Tigris Premier 3 3\* cylinder, Apecs AP 3\* cylinder or Apecs XS 1\* cylinder or UAP Plus 1\* rated cylinder incorporating zero lift or Carlisle Brass/Eurospec 1\* cylinder
  - Royde & Tucker LP08-44 / LP08-54 letterplate or UAP Limited 'The Soterian' letterplate (both optional)
  - Eurospec Enduromax High Efficiency Concealed Door Closer DCC2024CF/SV (44mm & 54mm Strebord only) or Geze Boxer 2-4 Concealed Closer 9728 (44mm Strebord only) or Dorma Door closer TS72V BC or Arrone Overhead Closer AR450 (44mm Streboard & Flamebreak only) or Arrone Overhead Closer AR1500 or Arrone Overhead Closer AR8300 or Arrone Overhead Closer AR8200 (all optional)

For the full specification of the product please refer to the constructional specification that accompanies this certificate.

## CERTIFICATE No CS 5082 DOORPAC LTD

### Doorpac Ltd – Homeguard Internal Security Doorsets

Configuration	Maximum door leaf width (mm)	Maximum door leaf height (mm)	Door leaf thickness (mm)
Open-in, single leaf – GU Secury lock (Flamebreak & Strebord 44 leaf)	926	2040	44
Open-in, single leaf – Salto mortice locks (Strebord 54 leaf)	926	2040	54
Open-in & open-out, single leaf – Dorma night latch (Strebord 54 leaf)	926	2040	54
Open-in, single leaf – GU Secury lock (Strebord 54 leaf)	987	2264	54

**Table 1. Permitted Door Leaf Dimensions**

Configuration	Maximum frame width (mm)	Maximum frame height (mm)
Single 44mm leaf without toplights & sidelights	1000	2085
Single 54mm leaf without toplights & sidelights	1060	2295

**Table 2. Permitted Frame Dimensions**

**Note:** Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

8. The doorsets shall be mechanically fixed to wall constructions as described in manufacturers approved installation instructions.
9. Labels to the CERTISECURE design referencing CERTISECURE, PAS24 D, Doorpac Ltd, and CERTISECURE certificate No. CS 5082 shall be affixed to each doorset in the prescribed position.



---

**CERTIFICATE No CS 5082**  
**DOORPAC LTD**

---

10. This approval relates to on going production. The doorset and/ its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.

**Further Information**

Further information regarding the details contained in this report may be obtained from Doorpac Ltd, 2 Ranskill Ct, Sheffield, South Yorkshire, S9 5FZ (Tel: 0114 256 1615)

Further information regarding CERTISECURE certification and other approved products can be obtained from Warringtonfire Testing and Certification, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646777).